



**KNIGHT FIRE & SECURITY PRODUCTS
LTD**
Unit 84, Seawall Road Industrial
Estate

Tremorfa, Cardiff CF24 5TH

Tel: 029 2048 8129

Fax: 029 2048 9132

<mailto:info@knightfireandsecurity.com>



INSTALLATION INSTRUCTIONS
DOUBLE PUSH PANIC BUTTON

GRADE 3 DOUBLE PUSH PANIC BUTTON

Part Code: KP6

Security Grade 3

Environmental Class 2

Manufactured to EN50131

With Lid Tamper Reed

CE



Connect your alarm circuit wires to terminals T1 and T2, pre-wired to the Microswitch. This will create the circuit. Once the button is pressed in the circuit will be broken.

Attach your tamper wires to the 2 terminals with the reed. If the lid is removed the tamper will activate.

Other terminals are spare.

