



**KNIGHT FIRE & SECURITY PRODUCTS LTD**


Unit 84, Seawall Road Industrial Estate  
 Tremorfa, Cardiff CF24 5TH  
 Tel: 029 2048 8129  
 Fax: 029 2048 9132

[www.knightfireandsecurity.com](http://www.knightfireandsecurity.com)

Surface contact 4 terminal  
c/w selectable resistors and Tamper

**Product Code :XEND21**

Security Grade 3 Environmental Class 2  
 Manufactured to BS EN50131 – 2 - 6



**Description**

The XEND21 is a surface mount contact with integral tamper switch. It can be wired in traditional or fully supervised (EOL) formats and benefits from installer selection of End of Line (EOL) and Alarm contact bypass resistors.

**Installation**

Fix the contact to the mounting surfaces using the screws provided. The magnet should be installed parallel to the long face of the contact. Ensure the Green Labels line up.

Operation gap is 0 – 12mm .






**Wiring**

Traditional (4 wire) - Ensure no jumpers are fitted. Use all four terminals as marked.

Supervised (EOL) - Fit the appropriate jumpers for the Control Panel (see table right).

Connect the loop wires to the outer terminals - marked \*.

Other - Some applications may not require both resistors. In these cases fit jumper(s) in EOL or Alarm position as appropriate.

Control Panel	Value		Jumper positions		Jumper positions shaded
	EOL	Alarm	EOL	Alarm	
Honeywell Ademco	1K	1K	A	1	
Scantronic, Menvier, Texecom, Pyronix, Castle	2K2	4K7	BC	2	
Aritech	4K7	4K7	C	2	
Gardtec	4K7	6K8	C	3	
Guardall	8K2	8K2	B	24	
DSC	5K6	5K6	D	34	