



**KNIGHT** FIRE & SECURITY PRODUCTS LTD  
Unit 84, Seawall Road Industrial Estate  
Tremorfa, Cardiff CF24 5TH  
Tel: 00 44 29 20 48 81 29  
Fax: 00 44 29 20 48 91 32  
<mailto:info@knightfireandsecurity.com>



## INSTALLATION INSTRUCTIONS SINGLE PUSH PANIC BUTTON

**Part Code: KP1S Security Grade 1 Environmental Class 2 With Lid Tamper & Reed**



❶ Screw the unit base to mounting surface.

❷ Connect your alarm circuit wires to the reed terminals T1 and T2. This will create the circuit. Once the button is pressed in the circuit will be broken.

❸ Attach your tamper wires to terminals T3 and T4. If the lid is removed the tamper will activate.

Other terminals are spare.

❹ Carefully fit the lid to the central post on the base.

❺ Ensure no snagging occurs.

❻ Operation:- Push End button inwards.

❼ Reset :- by using the reset key (supplied)

